

LOOS & CO., INC.  
Break Strength Certified-Color Coded-Prestretched  
SEISMIC WIRE ROPE/CABLE BRACING ASSEMBLY



MINIMUM OF  
1/2 BEAM DEPTH  
BUT  
NOT LESS THAN 3"

CABLE ASSEMBLY W/  
STAKE EYE END  
SHOWN THIS SIDE

CABLE ASSEMBLY W/  
URC CLIP END  
SHOWN THIS SIDE

OVAL SLEEVE

Maintain a MINIMUM of  
1 1/2 pipe diameters  
from the side of the pipe  
to the oval sleeve.

Pipe clamp, grooved coupling,  
fitting, or other device at a  
fixed location on braced pipe.

# SEISMIC WIRE ROPE/CABLE BRACING Longitudinal Bracing

